



GO PROGRAM
Prescriptive HVAC
Incentive Application Form
Toll Free Hotline: 844-371-6704



MINIMUM EFFICIENCY LEVELS/ INCENTIVE LEVELS

Table 1: Air Conditioning Systems

Air Cooled Unitary and Split (new condenser and new coil) Air Conditioning Systems			
Equipment Capacity (Tons)	Equipment Capacity (Btuh)	Minimum SEER/EER	Maximum Incentive (\$/Ton)
< 5.4	< 65,000 Split	15.0 SEER/12.5 EER	\$125
< 5.4	< 65,000 Packaged	15.0 SEER/12.0 EER	\$125
≥ 5.4 to < 11.25	≥ 65,000 to < 135,000	12.0 EER	\$80
≥ 11.25 to < 20	≥ 135,000 to < 240,000	12.0 EER	\$80
≥ 20 to < 63	≥ 240,000 to < 760,000	10.8 EER	\$50
≥ 63	≥ 760,000	10.2 EER	\$50
Variable Refrigerant Flow Multi-Split Air Conditioning Systems			
Equipment Capacity (Tons)	Equipment Capacity (Btuh)	Minimum SEER/EER	Maximum Incentive (\$/Ton)
< 5.4 Tons	< 65,000 Btuh	15.0 SEER/12.5 EER	\$175/Ton

Table 2: Air Cooled Heat Pump Systems

Equipment Capacity (Tons)	Equipment Capacity (Btuh)	Minimum SEER/EER	Maximum Incentive (\$/Ton)
< 5.4	< 65,000 Split	15.0 SEER/12.5 EER & 9.0 HSPF	\$125
< 5.4	< 65,000 Packaged	15.0 SEER/12.0 EER & 8.5 HSPF	\$125
≥ 5.4 to < 11.25	≥ 65,000 to < 135,000	11.5 EER	\$80
≥ 11.25 to < 20	≥ 135,000 to < 240,000	11.5 EER	\$80
≥ 20	≥ 240,000	10.5 EER	\$50
Variable Refrigerant Flow Multi Split Heat Pump Systems			
< 5.4 Tons	< 65,000 Btuh	15.0 SEER/12.5 EER & 9.0 HSPF	\$175/Ton
Water Source Heat Pump Systems			
Equipment Capacity (Tons)	Equipment Capacity (Btuh)	Minimum SEER/EER	Maximum Incentive (\$/Ton)
< 11.25	< 135,000	14.0 EER	\$80
High Efficiency Energy Star [®] Mini-Split Pump Systems			
BTU Size Range	Minimum SEER	Minimum HSPF	Incentive
9,000 to 18,000	18	12	\$1,000/Unit

Table 3: Energy Saving Control and Fan Motor Options (When installed with new, qualifying equipment)

Air Cooled Unitary and Split (new condenser and new coil) Air Conditioning Systems		
Type of Measure	Additional Information	Incentive
Dual Enthalpy Economizer	Outside air economizer utilizing 2 enthalpy sensors (1 for outdoor and 1 for return air)	\$250/Unit
Demand Control Ventilation	Outside air intake controlled based on CO2 sensor	\$200/Unit
Electronically Commutated Motors (ECMs) for HVAC Fans	ECMs installed on fan powered terminal boxes, fan coils or HVAC supply fans on small unitary equipment	\$150/Motor