

South Hadley Electric Light Dept IFB for the Telecom Substation Improvements

A. Is this sketch suggesting that the existing pavement no longer needs to be removed per the hatch pattern on the C1.10 Site Preparation and Demolition Plan for the college street site? The removal and replacement will only be limited to the boxed area shown below?

*That is correct, the removal of existing pavement and installation of new porous pavement is limited to only the area outlined in red.*

