

ADDENDUM ACKNOWLEDGEMENT

Power & Telecom Materials IFB #2026A

1. Addendum Acknowledgement Form

Acknowledge receipt of the addenda in the space provided on the Addendum Acknowledgement Form. **Proposers must include the signed form with their Bid Proposal, even if not bidding on the part listed in the addendum.** Failure to do so will subject Proposers to disqualification.

2. Changes and Clarifications

See Information in this acknowledgment

ACKNOWLEDGEMENT FORM

As required by the RFP, Proposers must submit this acknowledgement form with their response. One acknowledgement form per response listing all addenda.

Addendum No.: #1

Addendum No.: ___

Addendum No.: ___

Company Name: _____

Representative's Name: _____

Signature: _____

Date: _____

Please review, sign, and return this complete addendum acknowledgement with your proposal.

Addendum#1

Power & Telecom Materials IFB #2025B

11/6/2025

Q1. In going through the bid, I noticed that a lot of the material is schedule 80 and for some of the material, schedule 80 is not possible. Was this just put on every piece of material and does it all have to be schedule 80?

A1. Please bid schedule 80 on conduit.

Q2. Do you accept crosses or does it need to be the exact manufacturer and part # requested?

A2. We accept crosses but you must add a notation of the manufacturer and the part number in the description area. Please bold or highlight it.